

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE REGULATORY CONTACT RECORD

Date/Time: 11-3-04 / 0900

Site Contact(s): Randy Leitner, Jay Britten
Phone: 303-966-3537

Regulatory Contact: Denise Onyskiw
Phone: 303-966-6687

Agency: CDPHE

Purpose of Contact: Discuss GB 118, Room 3803, B374 Remaining Structure

Discussion

Building 374, Room 3803, contained Glovebox 118 that ran from the floor of Room 3803, through the ceiling, and into the mezzanine level Room 4805. A partial area of the ceiling of Room 3803 and floor of Room 4805 was part of the glovebox structure. This glovebox has been removed during stripout of these rooms. As such, there is a large area of this ceiling/floor that remains contaminated. In addition, this area includes structural beams and smaller pieces of glovebox metal that are welded to these beams. The removal of these structural beams prior to demolition would be extremely cumbersome and would possibly create instability in the floor loading of this area. Kaiser-Hill will leave the area of the ceiling/floor inside the perimeter of the removed glovebox as contaminated and remove this portion during demolition as low-level waste. All contamination will be fixed. This area will be painted with high visibility paint and surveyed to verify no removable contamination (this is also required for the establishment of isolation controls for Pre-Demolition survey). This approach will be discussed in the Pre-Demolition Survey Report associated with this area.

After a discussion and walk-down of the area, Ms. Onyskiw agreed with this approach.

Contact Record Prepared By: Randy Leitner

Required Distribution:

M. Aguilar, USEPA
S. Bell, DOE-RFPO
B. Birk, DOE-RFPO
C. Deck, K-H Legal
Contact Record 4/10/00
Rev. 5/24/04

R. Leitner, K-H 371/374
J. Mead, K-H ESS
G. Morgan, DOE-RFPO
S. Nesta, K-H RISS


Additional Distribution:

D. Onyskiw, CDPHE
W. Seyfert, DOE/RFPO

ADMIN RECORD

D. Foss, K-H 707/776/777
S. Garcia, USEPA
C. Gilbreath, K-H 771/774
S. Gunderson, CDPHE
J. Legare, DOE-RFPO

K. North, K-H ESS/MS
R. Schassburger, DOE-RFPO
D. Shelton, K-H ESS
C. Zahm, K-H Legal



2/2